

महाराष्ट्र राज्य सार्वजनिक आरोग्य सेवा

जिल्हा आरोग्य प्रयोगशाळा जळगांव

दूरध्वनी क्र.0२५७-२२२९२२९

E-mail : dphljal@gmail.com

पाणी नमुन्याचा सूक्ष्मजीवीय अहवाल

प्रति, :- Samyakt English Medium School, Erandol .
पाठविणाऱ्यांचे पत्र क्रमांक व दिनांक :- 5-2-2024
प्रयोगशाळा संदर्भ क्रमांक :- 760
नमुना घेतल्याचा दिनांक :- }
नमुना पोहचल्याचा दिनांक :- } 5-2-2024
परीक्षण सुरु केल्याचा दिनांक :- }

अ. क्र.	नमुन्याचे विवरण	परीक्षणाचे निष्कर्ष			इतर अभिप्राय
		प्रती १०० मि.ली. नमुन्यातील संभाव्य सूक्ष्मजंतूंची संख्या			
		कोलीफॉर्मस	थर्मोटॉलरंट कोलीफॉर्मस	इ. कोलाय	
1.	R.O. Water sample .	0	-	-	Fit for drinking .
<p>Note:- Above water sample is not collected by this Laboratory. It is assumed that representative sample is sent for analysis</p> <p>Govt. R. No. → 3219284.. R6.340/ - Date 5-2-2024.</p>					

अभिप्राय :- पिण्यास अयोग्य पाण्यावर योग्य प्रमाणात क्लोरिनची प्रक्रिया केल्यानंतर व सूक्ष्मजीवीय पुनतपासणीनंतर पिण्यास योग्य असल्याची खात्री झाल्यानंतर ते पाणी पिण्यासाठी वापरता येईल.

अहवाल क्रमांक : 417

दिनांक :- 14-02-2024

अभिप्राय तारने कळविण्यात दिनांक :-

प्रत सादर :

MANAGER

PRINCIPAL

(१) जिल्हा आरोग्य अधिकारी, जिल्हा आरोग्य कार्यालय, जिल्हा

Samyakt English Medium School Erandol Dist-Jalgaon

(२) शाल्यचिकित्सक, जिल्हा आरोग्य कार्यालय, जिल्हा

Junior Scientific Officer
District Public Health Laboratory
Jalgaon - 425 001

(३) गटविकास अधिकारी पंचायत समिती

REMARKS

1) Sample No. (s) 01 is/are potable / chemically fit for drinking purpose on the basis of analysed parameters only.

However, this / these water source/s can be used for drinking purpose only after proper treatment, disinfection and ascertaining it's bacteriological quality frequently or regularly.

2) Sample No. (s) — Contains —

However, if there is no any other alternate source available nearby then this / these water Source/s can be used for drinking purpose only after proper treatment, disinfection and ascertaining it's bacteriological quality frequently or regularly.

3) Sample No. (s) — Contains —

Hence, this / these water Source/s is / are chemically non-potable / unfit for drinking purpose on the basis of analysed parameters only.

HEALTH SERVICES

No. DPHCJA/C/480/2024

Date :- 27.02.2024

Forwarded With Compliments To : Head Master

Samyak English Medium School

Erondal Dist. Jalgaon

MANAGER

SAMYAK ENGLISH MEDIUM SCHOOL

Erondal Dist. Jalgaon.

PRINCIPAL

Samyak English Medium

School Erondal Dist. Jalgaon

With reference to letter No. : —

Dated :- 5/2/2024

es Rs. : 940/-

Junior Scientific Officer
District Public Health Laboratory
Jalgaon - 425 007

Receipt No. and Date : 3219284

5/2/2024

State / Regional / District / Sub Divisional Public Health Laboratory, Jalgaon

E-mail-ID :

Phone No. : 2229221

REPORT ON CHEMICAL EXAMINATION OF WATER FOR DRINKING PURPOSES

Date of Collection : — — Date of Receipt : — 5/2/24 Date of Examination : — 5/2/24
(All the Analytical Results are in mg./Litre except pH, Turbidity) onwards.

Sr. No.	TEST PARAMETER	(1) — R.O	(2)	(3)	BIS Specification 10500 : 2012 Normal Values	
					Desirable Limits	Permissible Limits
1.	Physical Appearance	<u>clear</u>			—	—
2.	Odour	<u>odour free</u>			Agreeable	Agreeable
3.	Turbidity (as N.T.U.)	<u>0.30</u>			1.0	5.0
4.	pH Value	<u>7.96</u>			6.5 to 8.5	No relaxation
5.	Chlorides (as Cl)	<u>29.0</u>			250	1000
6.	Nitrates (as NO ₃)	<u>0.0</u>			45	No relaxation
7.	Total Hardness (as CaCO ₃)	<u>46.0</u>			200	600
8.	Alkalinity (as CaCO ₃)	<u>64.0</u>			200	600
9.	Total Dissolved Solids	<u>145.0</u>			500	2000
10.	Iron (as Fe)	<u>0.08</u>			0.3	No relaxation
11.	Fluoride (as F)	<u>0.138</u>			1.0	1.5
12.	Other Tests (if any)	—				
13.						
14.						
15.						
16.						
17.						
18.						
19.						

20
SAMYAK ENGLISH MEDIUM SCHOOL
Erandol, Dist-Jalgaon.

PRINCIPAL
SAMYAK ENGLISH MEDIUM
SCHOOL ERANDOL DIST-JALGAON

- This report is restricted only for the Sample/s is Submitted to this Laboratory.
- This Sample/s is / are not Collected by this Laboratory.